

# IMPORTANCE OF INSPECTION OF THE OIL-OIL SHELL AND TUBE HEAT EXCHANGER FOR NEEDS OF SUSTAINABLE DEVELOPMENT AND ENVIRONMENTAL PROTECTION

Marko S. JARIC,  
Innovation Centre of the Faculty of Mechanical Engineering Belgrade, mjaric81@gmail.com  
Sanja Z. PETRONIC,  
The Academy of Applied Technical Studies Belgrade, spetronic@mas.bg.ac.rs  
Suzana POLIC,  
National Museum of Serbia,  
Katarina G. COLIC,  
Innovation Centre of the Faculty of Mechanical Engineering Belgrade, kcolic@mas.bg.ac.rs  
Zagorka M. BRAT,  
Gazprom Neft, Narodnog fronta 21, 21000 Novi Sad, Serbia, zagorka.brat@nis.eu

**Abstract.** Plant for oil stabilisation is enable to recovery and commercial exploitation of oil which is rectifying from excavated raw gas. Condensed hot liquid hydrocarbons that are separated from natural gas can be used to heat the fluid that enters in the process in which it is separated into liarder and lighter components. This paper presents the inspection of an oil heat exchanger and explains the importance of inspection regarding sustainable development and environmental protection. The visual test revealed some mechanical damages and surface corrosion; a liquid penetrant inspection method showed no cracks at the time of inspection. The thickness of the material is measured by ultrasound technique. Determination of corrosion rate and remaining life of oil-oil shell and tube heat exchanger is performed according to the API 510 and API 572 standards.

**Key words:** Oil-oil heat exchanger, inspection, ndt methods, corrosion rate, remaining life

Table 1 Design data of oil-oil shell and tube heat exchanger

	Shell side	Tube side
Design pressure (bar)	13	33
Design temperature (°C)	128	100
Operating temperature (°C)	98/70	45,7/70
Test pressure (bar)	16.9	42.9
Weld joint efficiency (%)	0.85	0.85
Fluid	Stabilized condensate (Hot-oil)	Wet oil (entering in process)
Volume (S/H) (m2)	4354/2.49	
Material of construction	SA516 Grade 70	



Figure 1. Oil-oil shell and tube heat exchanger

Visual inspection activities of the shell and tube heat



Figure 2. The tube bundle after cleaning - in good condition without visible damages and deformations



Figure 3. Surface corrosion was observed on the internal side of the tubes (all tubes were in the similar condition in time of inspection)

Table 2. Inspection plan for recertification pressure vessel

No.	Activity	Reference	Acceptance	Verify	Inspection Level		
		Document	Criteria	Document	Req'	MOG	CA
1	Review Document						
	- Drawing, Design/ Datasheet	ASME Sec. VIII	ASME Sec. VIII	General Drawing & Datasheet	Yes	R	R
	- NDT Equipment Calibration	ASME Sec. V	ASME Sec. V	Calibration Cert.	Yes	R	R
	- Previous Inspection Record	API 510	API 510	Inspection Workbook	Yes	R	R
	- Corrosion & Failure Threat	API 510	API 510	Corrosion Assessment	Yes	R	R
	- Advance NDT Procedure			NDT Procedure	No	A	R
2	Visual Inspection						
2A	External	Internal procedure	API 510	Visual Inspection Report	Yes	P	M/R
2B	Internal	Internal procedure	API 510	Visual Inspection Report	Yes	P	W
3	Extended Non Destructive Test						
3A	Scanning Wall (shell, head)	Internal procedure	ASME Sec. V	NDT Report	No	P & T	M/R
3B	Wall Thickness Check (Localized Scan)	API 510	API 510	NDT Report	Yes	P & T	M/R
3C	Hardness		ASME Sec. II	Hardness Report	No	P & T	M/R
3D	MT or PT on selected W. joints	Internal procedure	ASME Sec. V	NDT Report	Yes	P & T	M/R
3E	Other Advance NDT	API 510	ASME Sec. V	NDT Report	No	W	W
4	Calculation Check						
4A	Corrosion Rate Calculation	API 510	API 510	Calculation Report	Yes	P	R
4B	Remaining Life Calculation	API 510	API 510	Calculation Report	Yes	P	R
4C	MAWP Calculation (if derated)	API 510	API 510	Calculation Report	No	P	R
5	Hydrotesting	Internal procedure	ASME Sec. VIII	Hydrotest Report	Yes	P & T	W
6	Completed Pressure Vessel Inspection Work Book Report				Yes	P	R




Figure 4. Sketch of PT tested equipment




Figure 4. Sketch and results of UT thickness measurement of oil-oil heat exchanger



Figure 5. Results of PT tested of the weld joints a) 1 b)2 and c)6.

## The determination of corrosion rate and remaining life

The corrosion rate is calculated according to the API 510 and API 572 as a corrosion rate long time (LT) according to the following equations:

$$\text{Corrosion rate (LT)} = (\text{tinitial} - \text{tactual}) / \text{time between tinitial and tactual (years)}$$

$$\text{Corrosion rate (LT)} = (13.208 - 13.11) / 18$$

$$\text{Corrosion rate (LT)} = 0.005 \text{ mm/year}$$

Remaining life of the heat exchanger (in years) shall be calculated from the following formula:

$$\text{Remaining life} = (\text{tactual} - \text{trequired}) / \text{corrosion rate}$$

$$\text{Remaining life} = 22 \text{ years}$$

## Conclusions

This paper presents the plan and results of oil-oil shell and tube heat exchanger's inspection as an important part for the environment protection and sustainable development.

The inspection included visual testing, liquid penetrant testing and ultrasound thickness measurements. The inspection revealed no corrosion or any damage and all of the essential sections/components of the oil-oil heat exchanger is safe to operate until next scheduled inspection.

Corrosion rate is calculated according API 510 and API 572 is 0.005 mm/year, hence remaining life of the oil-oil shell and tube heat exchanger is 22 years. Next external inspection, internal inspection and ultrasonic thickness measurements at the same position should be performed within next five years. Also grounding connections electrical resistance is recommended also to be measured according to the requirements of API 510 and API 572 standards.